Refurnishing your Data Centre to reduce the Daniel Traynor, QMUL, CHEP2023 carbon footprint









History

Original facility built and commissioned in ~2004.

Built on a budget, with compromises and limited knowledge. Provided a 200KW facility over 22 racks on the 2nd Floor of half filled new Chemistry building. No raised floor, no hot/cold air containment, shallow depth, open racks.

By 2018 having to rely on 2nd hand parts to maintain chillers. During covid all old units broke, no more spare parts, left with only 150KW of replacement, temporary chillers.

Power distribution needed to be replaced (heat damage).

Need to support LHC + SKA +LSST +,... for ~ 15 more years.

clear that >15 year old facility needed refurbishment.







Boundary Conditions

Highly constrained site with protected historic buildings, cemeteries, conservation areas, parks, transport links.

Offsite data centres are full or costly, and have increased remote management overheads.

No alternative existing space suitable for new DC

No new build space for new DC till after 2030

Only option is to reuse the existing space

Need to plan for future expansion ~400KW



Boundary Conditions(2)

Data Centre



Our Data Centre is located in the Joseph Priestly (JP) building (chemistry)

Building Chillers 2* 300KW (redundant pair)

Original 6 condensers providing 200KW cooling

Electrical substation (building has plenty of electrical power capacity)

First Refurbishment Plan



Hot aisle containment with in row coolers

10KW(average) per rack, 26 racks, 2 rows, 260 KW total.

Dual 32 amps power feeds per rack

Chilled water circuit. 4+1 in row cooling per row, 17C water in, 23C out. High level piping. 26C cold / 41C hot aisle air temperature!

Reuse existing building chillers +dry (free) air cooler



DUAL-AISLE CEILING CONTAINMENT



QM has a what?



Queen Mary, University of London Heat Decarbonisation Plan

March 2022

Silver Energy Management Solutions Ltd St Clare House, 30/33 Minories London EC3N 1DD T: 020 3900 1509 Six year 30% carbon reduction target

Energy use: 30,610,159 kWh electricity; 25,762,996 kWh gas

Electricity is slowly becoming dominated by wind, solar, nuclear, hydro electric (i.e. becoming decarbonised

J.P building largest consumer of power (natural gas+electricity) on campus (Chemistry building has lots of ventilation).

Use heat from DC to replace Gas heating.

QM has a what? **District heating** system

Feilden

House

Joseph

Priestley





Buildings which are connected to the heat network

QMUL has a district heating system linking several buildings (This is unusual in the UK)

Plans to extend to student residencies

Gas fired boilers provide the heating

Use heat from DC to replace some of the gas heating.



Second Refurbishment Plan

- New power, floor, lighting, cable management
- 10KW(average) per rack, 39 racks, 3 rows, 390KW
- Redundant dual 32 amps power feeds per rack







Second Refurbishment Plan

- To connect the low grade waste heat (26C) from the DC we need to
 - Redundant heat pumps to turn heat in to 75C high grade hot water (water to water more efficient than air to water).
 - Heat exchanger to put heat into district heating system.
 - Water tanks to hold reservoir of hot and cold water + other works needed
- Extra row of 13 racks (+130KW capacity),
- Strip out then add new power, lights, floor, cable management.
- Double the cost of original plan needs to be justified to get the investment.



HM Treasury

THE GREEN BOOK

CENTRAL GOVERNMENT GUIDANCE ON APPRAISAL AND EVALUATION

2020

Department for Business, Energy & Industrial Strategy

VALUATION OF ENERGY USE AND GREENHOUSE GAS

Supplementary guidance to the HM Treasury Green Book on Appraisal and Evaluation in Central Government

Justification

Using UK Government "Green book" guide lines on project evaluation

Provides best practice to quantify the impact of a project - social, economic, environmental

We have used this "tool kit" to work out impact on CO2 emissions

Unfortunately electricity is 2-3 times more expensive than natural gas

For every 1KWh of heat pumped we consume an additional .3KWh for the heat pump! (~PUE1.3)

We have used this "tool kit" to work out payback time (inc discount rate)



Since 2018 the CO2 produced per KWh of electricity below that for KWh of natural gas

Justification



https://www.epa.gov/energy/greenhouse-gas-equivalencies-calculator

scheme: No Heat recovery	Full scope: Heat recovery & dry air cooler		
26	39		
260KW	390KW		
No	Yes		
0	8,172		
NAN	7		

1,819 years or driving a car, 135,000 trees after 10 years, 8 seconds of world CO2 production

Notes

- Project awaiting official sign off from senior management.
- Project has taken over two years (still waiting).
- limped along.
- Needed to justify extra spending in a way that was easy to understand.
- Air cooling only of computers, i.e. Do not have on chip water cooling option, may limit future computing options.

 Needed a project manger that understands building infrastructure, heating, electricity. Knows how to talk to the suppliers and can drive the project vitally important. Before we had one the project



Source: HadCET Creation Date: 23/08/2022 11:11 © Crown copyright



2022 was the fifth-warmest year on record

Annual global-average temperature (C) above the 1850-1900 reference level

1.5

The past eight years have been the warmest on record, according to Copernicus data



Source: Copernicus ECMWF • ERA5 dataset © FT





Years

Asia's projected increase in emissions is offset by decreases in **EU** and **US**

Power generation global emissions changes by region (million tonnes of CO_2)



Source IEA Electricity Market Report 2023 © FT



Note: percentages are relative to demand, so will exceed 100% if power is being exported

Time

9:55pm

Generation

18.4% other so

Hydroelectric 🕐



Other

National Grid: Live

The National Grid is the electric power transmission network for Great Britain

	Demand 27.3GW	=	Generation 23.0GW	+	Transfers 😮		
			2010 011				
iels			15.8% transfers				
	0.00GW 0.0%		Imports and exports				
	10.31GW 37.8%		🗖 Belgium 🕐		-0.08GW -0.3%		
			🔲 France 😮		3.77Gw 13.8%		
bles			🔲 Ireland 🕐		-0.98GW -3.6%		
	0.00gw 0.0%		🔲 Netherlands 🕐		-0.10gw -0.4%		
	7.35GW 27.0%		🔲 Norway 🕐		1.30GW 4.8%		
	0.30GW 1.1%		S	torage			
ources			🔲 Pumped storage 🕐		0.39GW 1.4%		
	3.58GW 13.1%						
	1.28GW 4.7%						
	0.15GW 0.6%						