# System Identification of superconducting cavity parameters with recursive least-squares algorithms

Volker Ziemann, Jefferson Lab

LLRF workshop, Newport News, VA

Disclaimer: presentation based on previously published work

PHYSICAL REVIEW ACCELERATORS AND BEAMS 26, 112003 (2023)

PHYSICAL REVIEW ACCELERATORS AND BEAMS 27, 032001 (2024)

Simulations of real-time system identification for superconducting cavities with a recursive least-squares algorithm

New method to measure the unloaded quality factor of superconducting cavities

Volker Ziemanno

Uppsala University, 75120 Uppsala, Sweden

Volker Ziemanno⁵\* Uppsala University, 75120 Uppsala, Sweden




## System identification

- Conceptually simplest case:
  - Determine system a in  $y_i = a x_i$ 
    - from input  $x_i$  and output  $y_i$
  - Solution:  $\mathbf{a} = \sum_i x_i y_i / \sum_i x_i^2$

 Only a little more tricky if a is a matrix and x and y are vectors




## System Identification of Superconducting Cavities



SysId: determine detuning  $\Delta\omega$  and bandwidth  $\omega_{12}$ , maybe  $Q_0$ 

## Cavity model



#### Dynamical system of envelopes real and imaginary, *I* and *Q*

$$\begin{pmatrix} \frac{dV_r}{dt} \\ \frac{dV_i}{dt} \end{pmatrix} = \begin{pmatrix} -\omega_{12} & -\Delta\omega \\ \Delta\omega & -\omega_{12} \end{pmatrix} \begin{pmatrix} V_r \\ V_i \end{pmatrix} + \begin{pmatrix} \omega_{12}R & 0 \\ 0 & \omega_{12}R \end{pmatrix} \begin{pmatrix} I_r \\ I_i \end{pmatrix}$$

#### Express *I* through forward current *I*<sup>+</sup>

$$\begin{pmatrix} \frac{dV_r}{dt} \\ \frac{dV_i}{dt} \end{pmatrix} = \begin{pmatrix} -\omega_{12} & -\Delta\omega \\ \Delta\omega & -\omega_{12} \end{pmatrix} \begin{pmatrix} V_r \\ V_i \end{pmatrix} + \begin{pmatrix} \omega_E R & 0 \\ 0 & \omega_E R \end{pmatrix} \begin{pmatrix} I_r^+ \\ I_i^+ \end{pmatrix}$$

$$\omega_{12} = \hat{\omega}/2Q_L \qquad \omega_E = \hat{\omega}/Q_E$$

#### Discretize with time step $\Delta t$

$$\vec{V}'_{t+1} = (\mathbf{1} + F) \vec{V}'_t + B \vec{I}_t^+ \quad \text{with} \quad F = \begin{pmatrix} -\omega_{12} \Delta t & -\Delta \omega \Delta t \\ \Delta \omega \Delta t & -\omega_{12} \Delta t \end{pmatrix}$$

$$B = \omega_E \Delta t R$$

#### Isolate the known and the unknown

$$|\vec{y}_{t+1}| = |\vec{V}'_{t+1} - \vec{V}'_t - B\vec{I}_t^+ = |\vec{F}\vec{V}'_t|$$

Jefferson Lab

#### Least squares

Rewrite the mixture of unknowns and known voltages to separate the unknowns

$$|\vec{y}_{t+1}| = \vec{V}'_{t+1} - \vec{V}'_t - B\vec{I}_t^+ = F\vec{V}'_t$$

$$|\vec{y}_{t+1}| = |G_t \vec{q}|$$

$$\vec{F}\vec{V}_{t}' = \begin{pmatrix} -\omega_{12}\Delta t & -\Delta\omega\Delta t \\ \Delta\omega\Delta t & -\omega_{12}\Delta t \end{pmatrix} \begin{pmatrix} V_{r}' \\ V_{i}' \end{pmatrix}_{t} = \begin{pmatrix} -V_{r}' & -V_{i}' \\ -V_{i}' & V_{r}' \end{pmatrix}_{t} \begin{pmatrix} \omega_{12}\Delta t \\ \Delta\omega\Delta t \end{pmatrix} = \vec{G}_{t}\vec{q}$$

Stack multiple copies, on for each time step

Stack multiple copies, on for each time step 
$$\begin{pmatrix} \vec{y}_2 \\ \vec{y}_3 \\ \vdots \\ \vec{y}_{T+1} \end{pmatrix} = U_T \begin{pmatrix} \omega_{12} \Delta t \\ \Delta \omega \Delta t \end{pmatrix} \quad \text{with} \quad U_T = \begin{pmatrix} G_1 \\ G_2 \\ \vdots \\ G_T \end{pmatrix}$$
 Solve in the least-squares sense with the Moore-Penrose pseudo inverse 
$$\vec{q}_T = \begin{pmatrix} \omega_{12} \Delta t \\ \Delta \omega \Delta t \end{pmatrix}_T = (U_T^\top U_T)^{-1} U_T^\top$$
 
$$\vec{q}_T = \begin{pmatrix} \omega_{12} \Delta t \\ \Delta \omega \Delta t \end{pmatrix}_T = (U_T^\top U_T)^{-1} U_T^\top$$
 Tedious to calculate  $(U_T^\top U_T)^{-1} U_T^\top$  for quickly growing  $U_T$ 

for quickly growing  $U_{\tau}$ 

$$\vec{q}_T = \begin{pmatrix} \omega_{12} \Delta t \\ \Delta \omega \Delta t \end{pmatrix}_T = (U_T^\top U_T)^{-1} U_T^\top \begin{pmatrix} \vec{y}_2 \\ \vec{y}_3 \\ \vdots \\ \vec{y}_{T+1} \end{pmatrix}$$

## Recursive least squares

Introduce  $P_T^{-1} = U_T^{\top} U_T$ , the inverse of empirical covariance matrix.

$$egin{aligned} P_{T+1}^{-1} &= U_{T+1}^{ op} U_{T+1} \ &= p_0 \mathbf{1} + G_1^{ op} G_1 + G_2^{ op} G_2 + \dots + G_T^{ op} G_T + G_{T+1}^{ op} G_{T+1} \ &= P_T^{-1} + G_{T+1}^{ op} G_{T+1}. \end{aligned}$$

Obtain the updated quantities  $p_{T+1}$  and  $q_{T+1}$  at the next time step by absorbing the new information from V' and y.

$$\begin{split} p_{T+1} &= \left[\frac{1}{1+p_T\vec{V}_T'^2}\right] p_T \\ &= \left[\frac{1}{1+p_T\vec{V}_T'^2}\right] p_T \\ &= \left[\frac{1}{1+p_T\vec{V}_T'^2}\right] p_T \left(\sum_{t=1}^T G_t^\top \vec{y}_{t+1} + G_{T+1}^\top \vec{y}_{T+2}\right) \\ &= \left[\frac{1}{1+p_T\vec{V}_T'^2}\right] (\vec{q}_T + p_T G_{T+1}^\top \vec{y}_{T+2}). \end{split}$$

## Forgetting factor a

for time-varying systems

• Time horizon  $N_f$  and  $\alpha = 1 - 1/N_f$ 

"discount factor"

$$P_{T+1}^{-1} = \alpha P_T^{-1} + G_{T+1}^{\top} G_{T+1}$$

• Update equations for  $p_T$  and  $\vec{q}_T$  from one timestep to the next

$$p_{T+1} = \left[\frac{1}{\alpha + p_T \vec{V}_T^2}\right] p_T$$

New  $y_{T+2}$  and  $G_{T+1}$  come from new currents I and voltages V'

$$\vec{q}_{T+1} = \left[ \frac{1}{\alpha + p_T \vec{V}_T'^2} \right] (\alpha \vec{q}_T + p_T \hat{G}_{T+1}^{\top} \vec{y}_{T+2})$$

#### Simulations

Cavity: 1 GHz,  $Q_L=5x10^5$ ,  $f_s=10$  MHz,  $N_f=100$ ,  $\sigma_p=10^{-4}$  V<sub>max</sub>,  $\sigma_m=10^{-3}$  V<sub>max</sub> Step in  $\omega_{12}$  2 kHz oscillation of  $\Delta\omega$ 


#### Current step


- Cavity starts charging
- observe wiggle after 0.5 ms
- Q-phase oscillates

#### Reconstructed parameters

- Bandwidth  $\omega_{12}$  doubles
- Frequency  $\Delta\omega$  varies (2 kHz)

Behavior is reconstructed faithfully





## Measuring the unloaded Qo

Hunting the little discrepancy between  $Q_E$  and  $Q_L$ 

$$|ec{y}_{t+1}| = |ec{V}_{t+1}' - ec{V}_t' = F ec{V}_t' + \omega_E \Delta t R ec{I}_t^+ \quad ext{with}$$

$$\vec{V}'_{t+1} - \vec{V}'_t = \vec{F} \vec{V}'_t + \omega_E \Delta t R \vec{I}_t^+$$
 with  $\vec{F} = \begin{pmatrix} -\frac{1}{2}(\omega_E + \omega_0)\Delta t & -\Delta \omega \Delta t \\ \Delta \omega \Delta t & -\frac{1}{2}(\omega_E + \omega_0)\Delta t \end{pmatrix}$ 

$$\omega_E = \hat{\omega}/Q_E$$
 $\omega_0 = \hat{\omega}/Q_0'$ 
 $\omega_0 = (1/Q_0 + 1/Q_0)$ 

Rewrite the right-hand side

$$FV'_{t} + \omega_{E}\Delta t R I_{t}^{+}$$

$$= \omega_{E}\Delta t \begin{pmatrix} -\frac{1}{2}V'_{r} + R I_{r}^{+} \\ -\frac{1}{2}V'_{i} + R I_{i}^{+} \end{pmatrix}_{t}$$

$$+ \Delta \omega \Delta t \begin{pmatrix} -V'_{i} \\ V'_{r} \end{pmatrix}_{t} + \omega_{0}\Delta t \begin{pmatrix} -\frac{1}{2}V'_{r} \\ -\frac{1}{2}V'_{i} \end{pmatrix}_{t}$$

$$= \begin{pmatrix} -\frac{1}{2}V'_{r} + R I_{r}^{+} & -V'_{i} & -\frac{1}{2}V'_{r} \\ -\frac{1}{2}V'_{i} + R I_{i}^{+} & V'_{r} & -\frac{1}{2}V'_{i} \end{pmatrix}_{t} \begin{pmatrix} \omega_{E}\Delta t \\ \Delta \omega \Delta t \\ \omega_{0}\Delta t \end{pmatrix}$$

$$G_{t}$$

Stack consecutive measurements on top of each other

→ least-squares problem

$$\begin{pmatrix} \vec{y}_{2} \\ \vec{y}_{3} \\ \vdots \\ \vec{y}_{T+1} \end{pmatrix} = U_{T} \begin{pmatrix} \omega_{E} \Delta t \\ \Delta \omega \Delta t \\ \omega_{0} \Delta t \end{pmatrix} \text{ with } U_{T} = \begin{pmatrix} G_{1} \\ G_{2} \\ \vdots \\ G_{T} \end{pmatrix}$$

Solve by Moore-Penrose

$$\vec{q}_T = \begin{pmatrix} \omega_E \Delta t \\ \Delta \omega \Delta t \\ \omega_0 \Delta t \end{pmatrix}_T = (U_T^\top U_T)^{-1} U_T^\top \begin{pmatrix} \vec{y}_2 \\ \vec{y}_3 \\ \vdots \\ \vec{y}_{T+1} \end{pmatrix}$$

251014, V. Ziemann

$$\vec{y}_{t+1} = G_t \vec{q}$$

SysId for cavities

#### Recursive ...

Technical difficulty: need to invert  $P_{T+1}^{-1}$  if new term is added

$$P_{T+1}^{-1} = U_{T+1}^{\top} U_{T+1}$$

$$= p_0 \mathbf{1} + G_1^{\top} G_1 + G_2^{\top} G_2 + \dots + G_T^{\top} G_T + G_{T+1}^{\top} G_{T+1}$$

$$= P_T^{-1} + G_{T+1}^{\top} G_{T+1}. \tag{12}$$

Woodbury matrix identity to the rescue

$$(A + VW^{\top})^{-1} = A^{-1} - A^{-1}V(\mathbf{1} + W^{\top}A^{-1}V)^{-1}W^{\top}A^{-1}$$

$$P_{T+1} = [\mathbf{1} - P_TG_{T+1}^{\top}(\mathbf{1} + G_{T+1}P_TG_{T+1}^{\top})^{-1}G_{T+1}]P_T$$

#### **Substitutions**

$$A^{-1} = P_T$$

$$V = G_{T+1}^{\top}$$

$$W^{\top} = G_{T+1}$$

With forgetting factor  $\alpha$ 

$$\begin{split} P_{T+1} &= \frac{1}{\alpha} [\mathbf{1} - P_T G_{T+1}^\top (\alpha + G_{T+1} P_T G_{T+1}^\top)^{-1} G_{T+1}] P_T \\ \vec{q}_{T+1} &= [\mathbf{1} - P_T G_{T+1}^\top (\alpha \mathbf{1} + G_{T+1} P_T G_{T+1}^\top)^{-1} G_{T+1}] \\ &\times \left( \vec{q}_T + \frac{1}{\alpha} P_t G_{T+1}^\top \vec{y}_{T+2} \right). \end{split}$$

## Critically coupled cavity


f=1GHz,  $Q_0=10^9$ ,  $Q_E=0.8x10^9$ ,  $N_f=\infty$ 

Algorithm does not work in steady-state, where the equations are degenerate → pulsed

Track small changes:

- $\rightarrow$  need larger sample time  $\Delta t$ ~ms
- $\rightarrow$  10 seconds real time

Fairly robust against small errors in shunt resistance *R* 





## Over-coupled cavity

 $Q_0=10^9$ ,  $Q_E=10^6$ 

Sampling time f<sub>s</sub>=0.1 ms six seconds real time

Also works with random errors in percent range


#### But!!!


Extreme sensitivity on systematic error of R


Use RLS calibration of R In steady-state


$$V'_t = R \left( I_t^+ + I_t^- \right)$$

Use RLS to continuously update R for many interations









12



#### Conclusions

- Recursive least-squares algorithms are a powerful tool to continuously improve estimates in real time
  - Computational effort per time step is moderate
  - Colleague in Uppsala has a working system running close to 10 MHz

